

CERTIFICATE OF COMPLIANCE WITH THE ORDER 2.1

According to EN 10204

HERZCON **4600XX** is a simple unit for connecting FCU with pipe centre distance of 65/90/120 mm. Under the HERZ quality management system, specific material, dimensional, and functional tests have been established, both with regard to the individual components and the complete product.

COMPONENTS / MATERIALS:

- Strainer with integrated drain-valve
- Combi Valve
- 2 Multifunction ball valves
- Insulation box

Housings	dezincification resistant brass
Diaphragm and seals	EPDM

MEASUREMENT / TECHNICAL DATA:

Measurement and technical data according HERZ standard sheet

Max. operating pressure: 16bar

Min. operating temperature: -20°C

Max. operating temperature: 130°C

The hot water purity is according to Austrian standard ÖNORM H 5195 and/or VDI specification 2035.

CONTROL:

The control of products (material, dimensional, and functional tests) during production is performed in accordance to the requirements of the EN ISO 9001:2015 certified Quality Management System.

Vienna, the 6th of April, 2020

HERZ Armaturen Ges.m.b.H



Ing. Wolfgang Rauch
Quality Manager



Certifikát zhody s nariadením 2.1

podľa EN 10204

HERZCON 4600 xx je samostatná jednotka na pripojenie FCU (jednotiek FanCoil) s osovou vzdialenosťou pripojovacieho potrubia 65 / 90 / 120 mm.

V rámci systému riadenia kvality HERZ boli zavedené špecifické materiálové, rozmerové a funkčné skúšky, a to tak s ohľadom na jednotlivé komponenty, tak aj na celý výrobok.

COMPONENTS / KOMPONENTY:

- Filter s integrovaným vypúšťacím ventilom
- Kombinovaný ventil
- 2 Multifunkčné guľové kohúty
- Izolačný box

Telo ventilov	z mosadze odolnej voči vyplavovaniu zinku
Membrána a tesnenie	EPDM

MEASUREMENT / TECHNICKE UDAJE:

Rozmery a technické údaje nájdete v technických listoch HERZ.

Max. prevádzkový tlak:	16 bar
Mim. prevádzková teplota:	-20°C (nemrznuca zmes)
Max. prevádzková teplota:	+130°C

Kvalita plniaceho média musí vyhovovať požiadavkám ONORM H 5195, resp. smernici VDI 2035.

KONTROLA:

Kontrola výrobkov (materiálových, rozmerových a funkčných skúšok) počas výroby je vykonávaná v súlade s požiadavkami certifikovanej kvality EN ISO 9001:2015 Systém manažmentu kvality.

Vienna, the 6th of April, 2020

HERZ Armaturen Ges.m.b.H



Ing. Wolfgang Rauch
Quality Manager